


## **LIGHTNING ROD**







To be fixed on Fixing pole (ref. 11042 / 11043 / 11044) + Extension masts (ref. 11037 / 11039 / 11041)

## **RADIUS OF PROTECTION**

Height (m)	Level I	Level II	Level III	Level IV
1	2.7	3.4	4.1	5.1
2	5.5	6.7	8.3	10.3
3	7.0	8.7	11.1	13.4
5	8.5	10.7	14.0	16.6
10	10.2	13.8	18.3	21.5
15	10.1	15.4	20.9	24.6
20	8.4	15.6	22.3	26.9

## **COMPLIANCE**

IEC 62561-2

Components for lightning protection systems (CSPF) - Part 2: Requirements for conductors and grounding electrodes







COMPLIES WITH IEC 62 561-2



contact@france-paratonnerres.com https//france-paratonnerres.com/en/